

**FLORENCE COUNTY, SC
INVITATION BID NO. 05-13/14
GREENWOOD PARK-PARKING LOT LIGHTING
ADDENDUM #1**

August 1, 2013

The following should be added to the Scope Of Work/Technical Specifications as No. 10 on Page 4 of Invitation to Bid No. 05-13/14:

The panel and lighting control cabinet should be mounted on a "metal angle iron" frame work that is independent of the pole.

If you have any questions concerning this addendum, please direct all inquiries by e-mail to pfletcher@florenceco.org.

**PLEASE ACKNOWLEDGE THIS ADDENDUM BY SIGNING BELOW AND
SUBMIT IT WITH YOUR BID.**

I have read and acknowledged this addendum to invitation to bid no. 05-13/14.

Authorized Signature

Printed Name

Date

Company Name