



Florence County Government
Procurement Department

April 6, 2015

**ADDENDUM NO.1- BUILDING RENOVATION OF NEW TOWN HALL IN OLANTA
(BID NO. 24-14/15)**

Florence County is sending to all interested contractors clarification information and answers to frequently asked questions (FAQs) concerning this invitation to bid. The answers are highlighted in **RED** and **underlined**. Please submit this addendum along with your bid.

1. What kind of windows are to be used for the pricing of the window alternate? **The new storm windows are to match the existing, which were evident at the Pre-bid.**
2. Should all shutters be painted? **Yes.**
3. What size crown moldings are to be used in the rooms? **4" nominal.**
4. What are the side dimensions of the cabinets? **2'-0" deep.**
5. What type of paint are to be used for the project? Sherman Williams Porter etc...? **No manufacturer is specifically called for. Exterior Latex to be compatible with existing paint/surface conditions. Color and sheen to match existing.**

PLEASE ACKNOWLEDGE THIS ADDENDUM BY SIGNING BELOW AND SUBMIT IT WITH YOUR BID.

I have read and acknowledged this addendum to invitation to bid no. 24-14/15.

Authorized Signature

Printed Name

Date

Company Name