

### Florence County Government

#### Procurement Department

March 10, 2016

## ADDENDUM NO.1- DESIGN/BUILD SERVICES-NEW MAINTENANCE BUILDING FOR THE TOWN OF SCRANTON (RFP# 06-15/16)

### The Following Changes Are Hereby Made To The Scope of Work of this RFP:

- 1. The RFP Scope of Work mentions a 12' x 14' OHD. This size cannot fit on a building with a 14' eave height. Therefore, the building eave height has been raised from 14' to 16'
- 2. There are not enough walk doors in the scope of work for this building to enter the shop for life safety purposes. Therefore, one (1) additional walk door has been added to the scope of work.

# PLEASE ACKNOWLEDGE THIS ADDENDUM BY SIGNING BELOW AND SUBMIT IT WITH YOUR PROPOSAL.

I have read and acknowledged this addendum for bid no. 29-14/15.		
Authorized Signature	Printed Name	Date
Company Name		

County Complex