



Florence County Government
Procurement Department

October 12, 2016

**ADDENDUM NO.1- RE-BID DESIGN/BUILD SERVICES-NEW MAINTENANCE
BUILDING FOR THE TOWN OF SCRANTON
(RFP NO. 11-16/17)**

Four questions are addressed in this Addendum. The answers are highlighted in **BOLD RED** and **UNDERLINED**.

1. On page 6 the Quality of the Interview was left blank.

Answer: This should be 100%.

2. The eave height is set at 12' and the overhead doors are also 12' tall; will the door height be reduced or the eave height raised?

Answer: The original specified bay door at 12' with 14' wall framing.

3. Will the Florence County Consider moving the deadline for the RFP back at least (1) one week in light of the impact of Hurricane Matthew?

Answer: The RFP deadline will be extended to Wednesday, October 26, 2016 @ 3:00 p.m.

4. Is the insulation energy efficiency insulation, 4" on the walls and 6 " in the roof?

Answer: Insulation for the building must comply with the 2009 energy efficiency code for Zone 3 (prescriptive for Zone 3).



Florence County Government
Procurement Department

YOU MUST ACKNOWLEDGE THIS ADDENDUM BY SIGNING BELOW AND SUBMITTING IT WITH YOUR BID.

I have read and acknowledged this addendum for RFP No. 11-16/17.

Authorized Signature

Printed Name

Date

Company Name: _____